

Product Quality Certificate

U-007418.009



Product : Jumpax® Strong

Holder : Unifloor Underlay Systems
Arnsbergstraat 24
NL 7418 EZ Deventer
The Netherlands

Impact sound reducing according to ISO 10140-3:2010 (wooden subfloor construction $I_{co} = -5$ dB)

Product	Test results	
Jumpax® Strong without floorcovering	$I_{co} + 3$ dB	+ 8 dB improvement
Jumpax® Strong with Cushion Vinyl 3 mm	$I_{co} + 4$ dB	+ 9 dB improvement
Jumpax® Strong with LVT glued 2,5 mm	$I_{co} + 3$ dB	+ 8 dB improvement
Jumpax® Strong with Linoleum 2 mm	$I_{co} + 4$ dB	+ 9 dB improvement
Jumpax® Strong with LVT click 4,5 mm	$I_{co} + 5$ dB	+ 10 dB improvement
Jumpax® Strong with click Laminate 8 mm	$I_{co} + 4$ dB	+ 9 dB improvement
Jumpax® Strong with GreenFloor® 3 mm and Linoleum 2 mm	$I_{co} + 6$ dB	+ 11 dB improvement
Jumpax® Strong with 2 cm EcoPearls® without floorcovering	$I_{co} + 8$ dB	+ 13 dB improvement
Jumpax® Strong with 2 cm EcoPearls® and Cushion Vinyl 3 mm	$I_{co} + 8$ dB	+ 13 dB improvement

Reference	Test date
Peutz, A 3227-1-RA	02-2018

Impact sound reducing according to ISO 10140-3:2010

Product	Test result	Test result
Jumpax® Strong without floorcovering	9 ΔL_{lin}	20 ΔL_w
Jumpax® Strong with LVT glued/selfadhesive 3,0 mm	8 ΔL_{lin}	20 ΔL_w

Reference	Test date
Peutz, A 3533-2E-RA	09-2018

Product Quality Certificate

U-007418.009



Fire rating classification according EN 13501:2007

Product	Test results
Jumpax® Strong	Dfl-s1

Reference	Test date
TÜV-89210247.77	04-2018

Unifloor Underlay Systems B.V.

Handwritten signature of Frank Vousten in black ink.

Frank Vousten
Product Manager

www.productquality.eu

Handwritten signature of Gerco Morsink in black ink.

Gerco Morsink
CEO